

BELL-MILAM-FALLS WSC
2020 Consumer Confidence Report

Annual Water Quality Report for the period of January 1, 2020 to December 31, 2020

For more information regarding this report contact Robert Jekel at (254) 697-4016.

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. To learn about future public meetings (concerning your drinking water), or to request to schedule one, please contact us. The board of directors meets each month at 462 W. FM 485, Cameron. Please call our office for the next schedule monthly meeting at (254) 697-4016 or (800) 826-4322.

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254) 697-4016.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

BELL MILAM FALLS WSC is a mixture of Purchased Surface Water and Groundwater.

Source Water Name	Type of Water	Report Status	Location	
1 - ROGERS PLANT	ROGERS PLANT	GW	Active	Trinity Aquifer
2 - BARTLETT	BARTLETT	GW	Active	Trinity Aquifer
SW FROM CENTRAL TEXAS	CC FROM TX0140161 CENTRAL	SW	Active	Stillhouse Hollow Lake

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Robert Jekel.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbialcontaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picrouries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)

2020 Regulated Contaminants Detected

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2018	1.3	1.3	0.22	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2018	0	15	2.8	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Maximum Residual Disinfectant Level	Collection date	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Units	Source of Disinfectant
Chlorine Residual, Chloramines	2020	1.60	0.51	4.0	4	4	ppm	Disinfectant used to control microbes.

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan-Dec 2020, our system lost an estimated 87,716,230 gallons of water. If you have any questions about the water loss audit please call our office.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2020	35	0 – 21.5	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year'								
Total Trihalomethanes (TTHM)	2020	69	13.8 – 46.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year'								
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2020	2.4	2.2 - 2.4	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2020	0.0499	0.0491 - 0.0499	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	2020	80	70 - 80	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.

Fluoride	2020	1.14	1.08 - 1.14	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2020	0.28	0.12 - 0.28	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2020	5.4	4.4 - 5.4	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2016	1.5	1.06 – 1.5	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	2016	5.4	0 – 5.4	0	15	pCi/L	N	Erosion of natural deposits.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2020	0.16	0 - 0.16	3	3	ppb	N	Runoff from herbicide used on row crops.

Violations

E. coli			
Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITOR GWR TRIGGERED/ADDITIONAL, MAJOR	05/08/2020	08/25/2020	We failed to collect follow-up samples within 24 hours of learning of the total coliform-positive sample. We completed Level 1 assessment as directed by TCEQ.
MONITOR GWR TRIGGERED/ADDITIONAL, MAJOR	10/09/2020	2020	We failed to collect follow-up samples within 24 hours of learning of the total coliform-positive sample. We completed Level 1 assessment as directed by TCEQ.

Central Texas Water Supply Corporation 2020 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorite	2020	0.536	0 - 0.536	0.8	1	ppm	N	By-product of drinking water disinfection.
Haloacetic Acids (HAA5)	2020	19	14.9 - 22.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year'

Total Trihalomethanes (TTHM)	2020	33	30.2 - 33.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
-------------------------------------	------	----	-------------	-----------------------	----	-----	---	--

* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year'

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2020	0.0484	0.0484 - 0.0484	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	2020	120	90 - 120	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	2020	0.3	0.25 - 0.26	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2020	0.14	0.14 - 0.14	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2020	0.13	0.12 - 0.13	3	3	ppb	N	Runoff from herbicide used on row crops.

Turbidity	Level Detected	Limit (Treatment Technique)	Violation	Likely Source of Contamination
Highest single measurement	0.6 NTU	1 NTU	N	Soil runoff.
Lowest monthly % meeting limit	100%	0.3 NTU	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

Chlorite

Some infants and young children who drink water containing chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.

Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING, ROUTINE (DBP), MAJOR	10/01/2020	10/31/2020	We failed to test our drinking water for the contaminant and period indicated. We completed routine sampling the following month and returned to compliance.

Public Notification Rule

The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).

Violation Type	Violation Begin	Violation End	Violation Explanation
PUBLIC NOTICE RULE LINKED TO VIOLATION	05/12/2015	02/24/2021	We completed the necessary steps to return to compliance.