

We're very pleased to present you with this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

About Our System

The Harmony Water Association (HWA) has been providing water service to its members for over 50 years. At this time, we serve approximately 2,350 connections in Clarke County. Our system extends to the Lauderdale and Jasper County lines and covers about 500 miles in the county. HWA works hard to provide top quality water to our members. HWA is overseen by a Board of Directors consisting of five (5) Members. All Board Members have received the required Board Management Training and two members have received Advanced Board Training. The board of directors along with management and employees attend training in order to continue to serve our members to the best of our ability. The HWA office is located at 118 Long Boulevard, Quitman, MS. The office is open Monday through Friday 8:00 AM to 4:30 PM. HWA maintains a busy year making repairs on all our well site buildings, casing water main lines in creek crossings, and performing routine maintenance on several elevated tanks. To better serve our members, HWA has recently added Automatic Meter Reading and our future plans are to upgrade water lines in several areas and add small extensions where feasible.

Contact & Meeting Information

If you have any questions about this report or concerning your water utility, please contact Operator, Daniel Dearman, at 601-776-2593 or 118 Long Blvd. Quitman. As our valued members, we want you to be informed about your water utility. If you want to learn more, please attend any of our regularly scheduled board meetings (by prior written request). HWA Board Meetings are held on the third Tuesday of every month at 5:00 PM at the Harmony Water Association office located at 118 Long Blvd. Quitman, MS 39355. HWA's Annual Meeting is held the third Monday of each October. No prior request to attend is necessary and members will receive a notice of location and time.

Source of Water

Our water source is from wells drawing from the Sparta Sand and Lower Wilcox Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request.

Period Covered by Report

We routinely monitor for contaminants in your drinking water in accordance with federal and state laws. These annual reports are based on results of our monitoring period of January 1 to December 31 of the calendar year prior to the date of this report. In cases where monitoring wasn't required in within a particular calendar year, the table reflects the most recent testing done in accordance with the laws, rules, and regulations.

As water travels over the land or underground, it dissolves naturally-occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

Terms and Abbreviations

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL): The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per billion (ppb) or Micrograms per liter: one part by weight of analyte to 1 billion parts by weight of the water samples.

Parts per million (ppm) or Milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water samples.

PWS #120005 Harmony Well #2 Sparta Sand Aquifer / Moderate susceptibility to contamination
Harmony Well #3 Lower Wilcox Aquifer / Lower susceptibility to contamination

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected (Your Water)	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
Arsenic #3	N	2024*	.0005	No Range	ppb	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium #3	N	2024*	.0056	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium #3	N	2024*	.0013	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper	N	1/1/2023 to 12/31/2025	0.0444	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride #3	N	2024*	.247	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead	N	1/1/2023 to 12/31/2025	0.0007	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Thallium	N	2020*	.0007	No Range	ppb	0.5	2	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
Sodium #3	N	2024*	112	No Range	ppm	20	60	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfectant By Products								
HAA5	N	2025	0.0	0.0 – 1.5	ppb	n/a	60	By-product of drinking water disinfection
TTHM (Total Trihalomethanes)	N	2025	1.0	0.0 – 1.0	ppb	n/a	80	By-product of drinking water disinfection
Chlorine	N	1/1/2025 To 12/31/2025	0.70	0.40 to 1.00	ppm	MRDLG = 4	MRDL = 4	Water Additives; used to control microbes

*Most recent sample. No sample required (or) results below reporting threshold current reporting period

PWS #120016 -- #2, #3, #4 – Sandy Basin & Hwy 514 Wells – Lower Wilcox Aquifer / Lower susceptibility to contamination

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected (Your Water)	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	-----------------------------	--	------------------	------	-----	--------------------------------

Inorganic Contaminants

Arsenic	N	2020*	.0005	n/a	ppb	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	2025	.0069	n/a	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	N	2025	.0006	n/a	ppm	0.1	0.1	Discharge from steel and pulp mills; erosion of natural deposits
Copper # 4	N	1/1/2023 To 12/31/2025	0.09	n/a	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Cyanide #3 #4	N	2021*	0.0403	n/a	ppb	200	200	Discharge from steel /metal Factories: discharge from Plastic and fertilizer factories
Fluoride	N	2025	.11	n/a	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead #4	N	1/1/2023 To 12/31/2025	0.0016	n/a	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Thallium	N	2020*	.0006	n/a	ppm	0.5	.002	Leaching from ore processing sites: discharge from electronics, glass and drug factories
Sodium #2 #3 #4	N	2024*	71 69.7 68.9	n/a	ppm	20	60	Road Salt, Water Treatment Chemicals, Water Softeners Sewage Effluents

Disinfectant By Product

HAA5	N	2025	0.0	0.0 – 0.0	ppb	n/a	60	By-product of drinking water disinfection
TTHM (Total Trihalomethanes)	N	2025	4.0	0.0 – 4.0	ppb	n/a	80	By-product of drinking water disinfection
Chlorine	N	1/1/2025 to 12/31/2025	0.70	0.40 to 1.19	ppm	MRDLG = 4	MRDL = 4	Water Additives; used to control microbes

*Most recent sample. No sample required (or) results below reporting threshold current reporting period

PWS #120018 Elwood – Lower Wilcox Aquifer / Lower susceptibility to contamination

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected (Your Water)	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
Arsenic	N	2025	.0007	No Range	ppm	.010	.010	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	2025	.0109	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	N	2025	.0009	No Range	ppm	0.1	0.1	Discharge from steel and pulp mills; erosion of natural deposits
Copper	N	1/1/2023 to 12/31/2025	0.3	No Range	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	N	2025	.149	No Range	ppm	4	4	Erosion of natural deposits: water additive which promotes strong teeth: discharge from fertilizer and aluminum factories
Lead	N	1/1/2023 to 12/31/2025	.001	No Range	ppm	.015	AL=.015	Corrosion of household plumbing systems, erosion of natural deposits
Thallium	N	2020*	.0005	No Range	ppb	0.5	2	Leaching from ore processing sites: discharge from electronics, glass, and drug factories
Sodium	N	2021*	97.2	No Range	ppm	20	60	Road Salt, Water Treatment Softeners and Sewage Effluents
Disinfection By Products								
HAA5	N	2025	6.0	0.0 – 5.7	ppb	n/a	60	By-product of drinking water disinfection
TTHM (Total Trihalomethanes)	N	2025	43.0	1.8 – 43.2	ppb	n/a	80	By-product of drinking water disinfection
Chlorine	N	1/1/2025 To 12/31/2025	0.70	0.60 to 0.85	ppm	MRDL G = 4	MRDL = 4	Water Additives; used to control microbes

*Most recent sample. No sample required (or) results below reporting threshold current reporting period

PWS # 120028 – North Enterprise #7 – Lower Wilcox Aquifer / Lower susceptibility to contamination

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected (Your Water)	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
Barium	N	2025	.0128	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Lead	N	1/1/2023 to 12/31/2025	0.0	No Range	ppm	.015	AL = .015	Corrosion of household plumbing systems, erosion of natural deposits
Copper	N	1/1/2023 to 12/31/2025	0.2	No Range	ppm	1.3	AL = 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Chromium	N	2025	.0006	No Range	ppm	0.1	0.1	Discharge from steel and pulp mills; erosion of natural deposits
Sodium	N	2024*	61.7	No Range	ppm	20	60	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfectant By Product								
HAA5	N	2025	0.0	0.0 – 9.7	ppb	n/a	60	By-product of drinking water disinfection
TTHM (Total Trihalomethanes)	N	2025	6.0	3.3 – 9.4	ppb	n/a	80	By-product of drinking water disinfection
Chlorine	N	1/1/2025 To 12/31/2025	0.90	0.59 to 1.20	ppm	MRDLG = 4	MRDL = 4	Water Additives; used to control microbes

*Most recent sample. No sample required (or) results below reporting threshold current reporting period

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

LEAD SERVICE LINE INVENTORY

Harmony Water Association has completed the Lead Service Line Inventory and no lead lines were found. The method used to make that determination was *visual inspection*.

LEAD EDUCATIONAL INFORMATION

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Harmony Water Association is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within you home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Harmony Water Association's General Manager at 601-776-2593. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. The MS Public Health Laboratory (MPHL) can provide information on lead and copper testing and/or other laboratories certified to analyze lead and copper in drinking water. MPHL can be reached at 601-576-7582 (Jackson, MS).

SIGNIFICANT DEFICIENCIES

During a sanitary survey conducted on 12/29/2025, the Mississippi State Department of Health cited the following significant deficiency(ies): Site Security for Harmony Water Association System #4, MS0120016. The system is scheduled to complete corrective actions by using a compliance plan or is within the initial 120 days minimum.

VIOLATIONS

As evidenced by the above table(s), our system has received no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water is safe at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some People may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from Safe Drinking Water Hotline 800-426-4791.

We at Harmony Water Association work hard to provide top quality water at every tap. We ask that all customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. This report is being published on the Web Page will not be mailed. Please call our office at 601/776-2593 if you would like a copy.

SIGN UP FOR ALERTS!!

Please encourage family, friends, and neighbors to visit our website at <https://harmonywater.myruralwater.com/> and sign up to receive our Alerts via text and/or email.